

சாதிப்பாடு தீயணைப்பு மற்றும் மீட்டிங் பிளனிங்
கீழ்பாக்கம் தீயணைப்பு மீட்டிங் பிளனிங் நிலையம்
தடை பரிசீலனை சான்று

பெண் எண். 182/2020

நாள்: 17/07/2020

சாதிப்பாடு எண். 21

பெயர்: தீயணைப்பு மீட்டிங் பிளனிங் துறை கீழ்பாக்கம் தீயணைப்பு மீட்டிங் பிளனிங்
நிலையம் பள்ளிக்கூடம் நிறுவன் / பள்ளிக்கூடத்திற்கு அங்கீகாரம்
வழங்கி தடை பரிசீலனை சான்று வழங்குவது குறித்து

- பெயர்: 01. அங்க அணை எண். 122, பள்ளி கல்வி (2) துறை, நாள் 14.09.2004
02. அங்க அணை எண். 123, பள்ளி கல்வி (2) துறை, நாள் 14.09.2004
03. பள்ளி முதன்மைப்பாளர் என்பவரிடமிருந்து பெறப்பட்ட விண்ணப்பம்
நாள்: 14/07/2020.

பெயர்: தீயணைப்பு மற்றும் மீட்டிங் பிளனிங் துறை கீழ்பாக்கம் தீயணைப்பு மீட்டிங் பிளனிங்
நிலையம், Damodharan Street, Kellys, Chennai - 600 010 என்ற முகவரியில்
பெயர்: M/s. SINDHI MODEL SENIOR SECONDARY SCHOOL” என்ற
பெயரில் 16.07.2020 அன்று, கீழ்பாக்கம் நிலைய அலுவலர் திரு. P. சிதம்பரம்
என்பவரால் ஆய்வு செய்யப்பட்டது. இவ்விடத்தில் பள்ளிக்கூடத்திற்கு அங்கீகாரம்
வழங்கி கீழ்க்கண்ட நிபந்தனைகளுக்கு உட்பட்டு (17.07.2020 முதல் 16.07.2021
மீட்டிங் தீயணைப்பு மற்றும் மீட்டிங் பிளனிங் நோக்கிலிருந்து யாதொரு தடையும் இல்லை.

CONDITIONS

1. This License is Valid for One Year from the date of issue.
2. Fire safety Systems should be maintained in good working conditions.
3. Mock drill to be conducted periodically with the help of local Fire Brigades.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per Sq.Metre as per the National Building Code-2005.
 - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c. As para 6.3 of the BIS Standards IS 14435-1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
 - d. Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e. Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Central District at Kilpauk.

பெயர்: The Principal,
M/s. SINDHI MODEL SENIOR SECONDARY SCHOOL
No.1, Damodharan Street, Kilpauk,
Chennai - 600 010.

நிலைய அலுவலர்
தீயணைப்பு (ம) மீட்டிங் பிளனிங் நிலையம்
கீழ்பாக்கம், சென்னை-600 010.

